



美商優力安全認證有限公司台灣分公司  
UL International, L.L.C., Taiwan Branch  
台北市 112 北投區大業路 260 號 1 樓  
1st Fl 260 Da-Yeh Road Peitou Taipei City Taiwan 112  
tel: 886-2-2896-7790 fax: 886-2-2891-7644  
<http://www.ul.com.tw>

## NOTICE OF AUTHORIZATION TO APPLY THE UL MARK

June 30, 2006

American Power Conversion Corp.  
132 Fairgrounds Rd Po Box 278 West Kingston  
RI 02892 U S A

Fax: (02)8913-1357

Reference: File E95463 Project 06CA32249

Product: FOR UL AND C-UL INVESTIGATION: UPS, MODELS BE500R, BE350R and BE550R

Dear Mr. Chen:

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.

UL's investigation of your products has been completed under the above project number and the subject products were determined to comply with the applicable requirements.

This letter temporarily supplements the UL Follow-Up Services Procedure and serves as authorization to apply the UL Listing Mark only at the factory under UL's Follow-Up Services Program to the subject products which are constructed as described below:

Identical to Models BE500R and BE350R covered in the Follow-Up Services Procedure, File E95463, Volume 1, Section 27 except upgrade operated ambient from 25°C to 40°C.

Model BE550R is similar to Model BE500R covered in the Follow-Up Services Procedure, File E95463, Volume 1, Section 27, which were submitted to UL for this investigation except upgrade output rating and alternate Transistors (Q14, Q18) from 55 V 100 A to 55 V, 75 A.

To provide the manufacturer with the intended authorization to use the UL Marks, the addressee must send a copy of this Notice and all attached material to each manufacturing location as currently authorized in File E95463, Volume 1.

This authorization is effective from the date of this Notice and only for products at the indicated manufacturing locations. Records in the Follow-Up Services Procedure covering the products are now being prepared and will be sent to the indicated manufacturing locations in the near future. Please note that Follow-Up Services Procedures are sent to the manufacturers only unless the Applicant specifically requests this document.

Products that bear the UL Mark shall be identical to those that were evaluated by UL and found to comply with UL's requirements. If changes in construction are discovered, appropriate action will be taken for products not in conformance with UL's requirements and continued use of the UL Mark may be withdrawn.

Sincerely,

**Richard Lee**

Richard Lee  
Project Engineer  
UL International, L.L.C., Taiwan Branch  
Tel: (02)2896-7790  
Fax: (02)28907442  
E-mail: Richard.Lee@tw.ul.com

Reviewed by:

**Joe Yang**

Joe Yang  
Senior Project Engineer  
UL International, L.L.C., Taiwan Branch  
E-mail: Joe.Yang@tw.ul.com

An independent organization working for a safer world with integrity, precision and knowledge

